












Building Energy Performance		Scotland						
Energy Performance Certificate	Calculated asset rating using IES <VE> 5.9.0.2 [SBEM]	Building type Prisons						
	<b>Current rating</b>							
	<b>Excellent</b>							
		<b>Carbon Neutral</b>						
		<b>A (0 to 15)</b>						
		<b>B (16 to 30)</b>						
		<b>C (31 to 45)</b>						
		<b>D (46 to 60)</b>						
	<b>E (61 to 80)</b>							
	<b>F (81 to 100)</b>							
	<b>G (100+)</b>							
 <b>G</b> Very Poor								
<b>Carbon Dioxide Emissions</b>								
The number refers to the calculated carbon dioxide emissions in terms of kg per m <sup>2</sup> of floor area per year		<b>104</b>						
Approximate current energy use per m <sup>2</sup> of floor area:		<b>350 kWh/m<sup>2</sup></b>						
Main heating fuel: Oil		Building Services: Heating with Nat. Vent.						
Renewable energy source:		Electricity: Grid supplied						
<b>Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment.</b>								
<b>Benchmarks</b>								
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating:		 <b>D+</b>						
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating:		 <b>F+</b>						
<b>Recommendations for the cost-effective improvement (lower cost measures) of the energy performance</b>								
<table border="0" style="width: 100%;"> <tr> <td style="width: 50%;">1. Improve insulation on HWS storage.</td> <td style="width: 50%;">4. Add optimum start/stop to the heating system.</td> </tr> <tr> <td>2. Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.</td> <td>5. Some windows have high U-values - consider installing secondary glazing.</td> </tr> <tr> <td>3. Consider replacing T8 lamps with retrofit T5 conversion kit.</td> <td>6. Add local time control to heating system.</td> </tr> </table>			1. Improve insulation on HWS storage.	4. Add optimum start/stop to the heating system.	2. Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.	5. Some windows have high U-values - consider installing secondary glazing.	3. Consider replacing T8 lamps with retrofit T5 conversion kit.	6. Add local time control to heating system.
1. Improve insulation on HWS storage.	4. Add optimum start/stop to the heating system.							
2. Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.	5. Some windows have high U-values - consider installing secondary glazing.							
3. Consider replacing T8 lamps with retrofit T5 conversion kit.	6. Add local time control to heating system.							

**Address:** Fort William Police Station High Street, Fort William, PH33 6EE

**Conditioned area (m<sup>2</sup>):** 1201

**Name of protocol organisation:** BRE, [00091]

**Date of issue of certificate:** 02 Jun 2009 (Valid for a period not exceeding 10 years)

This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.

**NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE**